



中国国家强制性产品认证证书

证书编号: 2012010308577391

委托人名称、地址

好利来(中国)电子科技股份有限公司
福建省厦门市湖里区枋湖路9-19号

生产者(制造商)名称、地址

厦门好利来电子电器有限公司
福建省厦门市湖里区枋湖路9-19号

生产企业名称、地址

厦门好利来电子电器有限公司
厦门市湖里区枋湖路9-19号

产品名称和系列、规格、型号

半导体设备保护用熔断体

HEA: Un: AC690V, DC500V; In: 125A, 160A, 180A, 200A; 额定分断能力: 80kA (690VAC), 50kA (500VDC); 分断范围和使用类别: aR

产品标准和技术要求

GB/T 13539.4-2009

上述产品符合强制性产品认证实施规则
CNCA-01C-012: 2007的要求, 特发此证。

发证日期: 2012年11月02日

有效期至: 2017年11月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0545848



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010308577391

NAME AND ADDRESS OF THE APPLICANT

Hollyland (China) Electronics Technology Corporation Ltd.
No. 9-19 Fanghu Road, Huli District, Xiamen City, Fujian Province, China

NAME AND ADDRESS OF THE MANUFACTURER

Xiamen Hollyland Electronics & Electric Co., Ltd.
No. 9-19 Fanghu Road, Huli District, Xiamen City, Fujian Province, China

NAME AND ADDRESS OF THE FACTORY

Xiamen Hollyland Electronics & Electric Co., Ltd.
No. 9-19 Fanghu Road, Huli District, Xiamen

NAME, MODEL AND SPECIFICATION

Fuse-links for the protection of Semiconductor Device

HEA: Un: AC690V, DC500V; In:125A, 160A, 180A, 200A; I1: 80kA(690VAC), 50kA
(500VDC); Breaking range and utilization category:aR

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2009

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-012:2007).

Date of issue: Nov. 02, 2012 Date of expiry: Nov. 02, 2017

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0545848