

0010 (HK)



# Certificate of Compliance

Certificate Number: LR 101178-1

Revision: LR 101178-3

Date Issued: July 29, 1996

Issued To: HOLLYLAND CO., LTD.  
12/F FLAT A, GEE LOK IND., BLDG.  
34, HUNG TO RD., KWUN TONG  
KOWLOON  
HONG KONG  
ATTENTION: MR. WILLIAM WONG, PRESIDENT

*The products listed below are eligible to bear the CSA Mark.*

*\*NOTE: The "NRTL/C" indicator may appear adjacent to the CSA Mark.*

Issued By: G. Lippa, C.E.T.  
Toronto, ON Canada

Signature

CLASS 1422 01 - FUSES - Special Type  
1422 81 - FUSES - Special Type - CERTIFIED TO U.S. STANDARDS

PRODUCTS

- Supplemental, glass cartridge fuses, non-renewable:
- Cat No 51NM and 52NM (pigtail lead) rated 32mA-8A, 250V ac and less IR125-10kA, IR250-\*, 5.2 by 20mm.
- Cat No 51S and 52S (pigtail lead) rated 32mA-8A, 250V ac and less IR125-10kA, IR250-\*, 5.2 by 20mm.

C 9 AUG 1996

\* The "NRTL/C" indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL and CSA Standards, for use in the U.S. and Canada. NRTL, i.e. Nationally Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.