



Certificate of Compliance

Certificate: 1246942

Master Contract: 161479 (LR 101178)

Project: 1246942

Date Issued: October 1, 2001

Issued to: **HOLLYLAND CO., LTD.**
12/F Flat A, Gee Lok Ind. Bldg.
34, Hung To Rd., Kwun Tong,
Kowloon, Hong Kong
Attention: Mr. William Wong, President

The products listed below are eligible to bear the CSA Mark shown



Issued by:

J. B. ...
J. B. ... P. Eng.

Authorized by:

B. Roesborough
B. Roesborough
Operations Manager

PRODUCTS

CLASS 1422 30 - SUPPLEMENTAL FUSES - Component Acceptance

Supplemental, glass cartridge fuses, non-removable:

- Cat No 52MS or 51MS(F), pigtail lead, rated 100mA-8A, 250V ac and less, IR125-10kA, IR250-*, 5.7 by 20mm.
- Cat No 62MS or 61MS(P), pigtail lead, rated 100mA-5A, 250V ac and less, IR125-10kA, IR250-*, 6.35 by 31mm.

Note: Types with IR250- have interrupting ratings of 35A for 1A or less, 100A for more than 1A to 3.5A, 200A for more than 3.5A to 10.0A, as applicable for the ampere ratings listed.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 248.1
CSA Std. C22.2 No. 248.14
T.I.L. CA-07

- Low-Voltage Fuses - Part I: General Requirements
- Low-Voltage Fuses, Part 14: Supplemental Fuses
- Component Acceptance Requirements for Supplemental Fuses