

접수번호 : 11-1920-1433
(Receipt No.)



전기용품안전인증서

Electrical Appliances Safety Certificate

안전인증번호
(Certificate No.) SU05008-8011A

제조업자명 : Hollyland (China) Electronics Technology Corporation Limited
(Factory)

대표자명 : William Wong H.K.
(President)

제조공장의
소재지 : No. 9-19, Fanghu Road, Huli District, Xiamen City, Fujian
(Factory Address) Province, P.R.China P.C. 361009

제품명 : 소형퓨즈(통형 퓨즈링크)(Miniature fuse(cartridge type fuse-link))
(Product)

기본모델명 : 65TS 15A
(Basic Model)

정격 : AC250V, 15A, 100A, a형
(Rating)

파생모델명 : 65TS(P) 15A, 65TS 12A, 65TS(P) 12A
(Series Model)

적용기준 : 일본 전기용품 기술기준
(Standard)

「전기용품안전 관리법 시행규칙」 제6조제2항에 따라 위의 전기용품에 대하여
안전인증서를 발급합니다.

We Issue Electrical Appliances Safety Certification as above product by Article 6 Section 2
of the Electrical Appliances Safety Control Law Enforcement Regulation.

2011년 03월 18일
year month day

kti 한국산업기술시험원장
KOREA TESTING LABORATORY



※ 이 인증서는 「전기용품안전 관리법」에 따른 전기용품 안전성 확인에 한정된 것이며, 그 밖의 다른
법률이 적용되는 제품의 경우에는 해당 법률에 따라 추가로 인증·허가 등을 받아야 합니다.

- 첨부 : 1. 안전관리부품 및 재질목록 (List of Critical Components)
(Annex) 2. 기본모델·파생모델의 내용 (General Descriptions of Certified Products)
3. 전기용품안전인증의 변경 현황 (Status of Certificate Revisions)

첨부 1 : 안전관리부품 및 재질목록
List of Critical Components

부품명 (회로기호) Component(Part no.)	제조사(상표명) Manufacturer(Brand)	모델명(형식) Model(Type)	정격 또는 특성 Rating or Characteristics	인증마크 Tested by
Element	Hollyland Chung Isilver	-	Ag plated Copper	-
	Fsp-on	-		
Cover cap	Nanjing Liqiao	-	Ni Plated Brass	-
	Fuzheng	-		
	Xinquan	-		
Case	Xinmao	-	Ceramic Tub	-
	Qifeng	-		
	Yingk	-		
Solder	Haiyuxin	-	Sn/Ag/Cu	-
	Hnada	-		
	Yunxi	-		
	Liqia	-		
Lead wire	Nanjing Liqiao	-	Tin Plated Copper	-
	Fuzheng	-		
	Xinquan	-		

유의사항 (Attention) :

1. 안전관리부품은 전기적인 안전에 직접적인 영향을 주는 부품으로서 안전인증기관이 정기공장검사 시 확인 관리 하는 사항입니다. 따라서 상기목록에 기재된 사항을 변경하거나 또는 복수등록을 원하시는 경우는 안전인증기관에 인증변경신청을 하여야 합니다.

As the "Critical components" are parts in directly related with safety, these components shall be checked during a factory inspection by the certification body. In case of applying multiple listing or changing the items above, the certification revision shall be applied.

2. 인증변경신청 없이 임의로 변경하는 경우는, 전기용품안전관리법 제 8 조제 1 항의 규정에 의한 안전인증 취소사유가 될을 유의하시기 바랍니다.

The Safety Certification will be cancelled under the Safety Control Law for Electrical Appliances, Paragraph 1 of Article 8 if the contents of the Certification is altered without our authorization.

첨부 2 : 기본모델 · 파생모델의 내용
General description of Certified Products

파생모델명 Derivative model	기본모델과의 차이점 Differences between the basic and derivative model(s)
65TS(P) 15A	Lead wire type(250 V 15 A 100 A a형)
65TS 12A	Rated current is changed(250 V 12 A 100 A a형)
65TS(P) 12A	Rated current is changed and lead wire type(250 V 12 A 100 A a형)
제품특기사항 및 시험조건 Remarks & Test conditions	
<p>1. Test Report Ref. No.: 08-1920-3029 (2008.07.01.)</p> <p>2. Product Description</p> <ul style="list-style-type: none"> - Miniature fuse(cartridge type fuse-link) - 250 V 15 A 100 A a형 - Ceramic case - Fixed fuse holder 	
<p><input type="checkbox"/> 본 제품의 시험내용에 관하여 문의하실 사항이 있으시면 아래 연락처로 문의하시기 바랍니다. 시험 담당자 / 연락처: 디지털산업본부 전기전자평가센터 조인철 / (02)860-1425</p> <p><input type="checkbox"/> If you have any question on product testing, please contact the person below : Job holder: Digital Industry Division, Electrics&Electronics Testing Center, INCHUL CHO/+82 2 8601-425</p>	

FP511-09-00

첨부 3 : 전기용품안전인증의 변경 현황
Status of Certificate Revisions

변경발급 내용 Contents of Certificate Revisions
<p>1st Rev.) Change of company name (11-1920-1433 : 2011.03.18.)</p> <ul style="list-style-type: none"> - Before : Xiamen Ningly Electronics Co., Ltd. After : Hollyland (China) Electronics Technology Corporation Limited

FP511-11-00